

Josh Berry

From: Peter Angelo
Sent: March-07-18 3:38 PM
To: Josh Berry
Cc: Garrett Osborne
Subject: Greenridge Farm Pit

Further to our dialogue and on-site meeting, we are in general support of the proposed development, although recommend the following in consideration of the TIS submission:

- 1) Construct new commercial entrance in accordance with CSAS-23 at the eastern limit of the subject lands, c/w 3.5 m wide 60.0 m right turn taper.
- 2) New entrance and taper to be hard surfaced with minimum 40 mm HL3 surface/50 mm HL8 binder HMA to limit of requisite platform
- 3) New entrance to include mud pad beyond limits HMA
- 4) New entrance profile shall be constructed with sufficient platform to provide requisite sightlines for egressing triaxle vehicles (ie. minimum per OPSD 301.010)
- 5) New entrance shall include 150 W HPS light standard (or equivalent LED) in consideration of near dark conditions during proposed 7-to-7 operational hours
- 6) Proponent shall provide surety for future resurfacing of Ridge Road across frontage of subject lands, as required from time to time for the duration of aggregate license (ie. on the order of 3.5mx2x.090x2.45x120xL)

P

Respectfully submitted,

Peter Angelo, P.Eng.

Development Engineer
Development Services Department
The Corporation of the County of Prince Edward
T: 613.476.2148 ext. 2006 | F: 613.471.2050
pangelo@pecounty.on.ca



280 Picton Main Street, Picton, ON, K0K 2T0
Mailing Address: 332 Picton Main Street, Picton, ON K0K 2T0
www.thecounty.ca | [facebook](#) | [twitter](#)

This communication is intended for the addressee indicated above. The information contained in the email will be used for municipal purposes and will be managed in accordance with *The Municipal Act* and *The Municipal Freedom of Information and Protection of Privacy Act*. If you have received this in error, please notify us immediately.